

VOC Content Test Certificate

Friday October 2nd, 2009

Manufacturer: Protect Crete Pty Ltd (14/137 Rooks Road, Nunawading Victoria 3131)


Sample Description: Moisture-Fix

Date Tested: September 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Moisture-Fix
Interior Sealer 65 grams per Litre as VOC content coating	<1 grams per Litre as VOC content per coating
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Moisture-Fix
Interior Sealer 65 grams per Litre as VOC content coating	<1 grams per Litre as VOC content per coating



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0909-30