

VOC Content Test Certificate

Thursday, 3rd December 2015

Manufacturer: Oxtek Australia Pty Ltd (3-174 Atlantic Drive, Keysborough, VIC, 3173)


Sample Description: X520 Warehouse

Date Tested: December 2015 (Tested by FORAY Laboratories – NATA Accreditation 1231)


Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

| | |
|---|---|
| Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11 | X520 Warehouse |
| Internal Sealer 65 grams per Litre as VOC content per mate | <1 grams per Litre as VOC content per material |
| Specification Green Building Council of Australia Green Green Star Office Design V3 IEQ-13 | X520 Warehouse |
| Internal Sealer 65 grams per Litre as VOC content per material | <1 grams per Litre as VOC content per material |



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Nick Joy
BSc (Hons)
Consultant

CV151201