

X 220



Professional Scientific Solutions

# VOC Content Test Certificate

Friday October 2<sup>nd</sup>, 2009

Manufacturer: Protect Crete Pty Ltd (14/137 Rooks Road, Nunawading Victoria 3131)

Sample Description: Moisture-Fix

Date Tested: September 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings.

Test Data:

Specification	Moisture-Fix
<b>Green Building Council of Australia</b> <b>Green Star Office Design V2 IEQ-13</b> <b>Green Star Office Interiors V1.1 IEQ-11</b>	
Interior Sealer 65 grams per Litre as VOC content coating	<1 grams per Litre as VOC content per coating
Specification	Moisture-Fix
<b>Green Building Council of Australia</b> <b>Green Star Office Design V3 IEQ-13</b>	
Interior Sealer 65 grams per Litre as VOC content coating	<1 grams per Litre as VOC content per coating

Dr. Vyt Garmys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

F0909-30