

X 300



OHS & Environmental Care

VOC Content Test Certificate

Friday October 2nd, 2009

Manufacturer: Protect Crete Pty Ltd (14/137 Rooks Road, Nunawading Victoria 3131)

Sample Description: Surface Repeller

Date Tested: September 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC)
Content of Paints and Related Coatings.

Test Data:

<p>Specification</p> <p>Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11</p>	<p>Surface Repeller</p>
<p>Interior Sealer 65 grams per Litre as VOC content coating</p>	<p><1 grams per Litre as VOC content per coating</p>
<p>Specification</p> <p>Green Building Council of Australia Green Star Office Design V3 IEQ-13</p>	<p>Surface Repeller</p>
<p>Interior Sealer 65 grams per Litre as VOC content coating</p>	<p><1 grams per Litre as VOC content per coating</p>

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0909-30

Sustainability

Advanced Laboratory/Analytical Services

Technology & Innovation