

X 260



Professional Scientific Solutions

OHS & Environmental Care

VOC Content Test Certificate

Monday 6th May 2019

Supplier: Oxtek Australia (PO Box 4455, Dandenong South, VIC, 3164).

Sample Description: X260 MEDI-VET

Date Tested: May 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Sustainability

Test Data:

Specification	
Green Building Council of Australia Green Star Design & As Built V1.1 13.1.1 Green Star Interiors V1.1 12.1.1B	X260 MEDI-VET
Primers, sealers and prep coats: 65 grams per Litre as VOC content per material	<1 gram per Litre as VOC content per material
<i>We hereby certify X260 MED-VET is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i>	

Advanced Laboratory/Analytical Services

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Tuan Duong
BE (Chem. Eng.)
Consultant

Nick Joy
BSc (Hons)
Consultant

Technology & Innovation

CV190502