



# VOC Content Test Certificate

Thursday, 3<sup>rd</sup> December 2015

Manufacturer: Oxtek Australia Pty Ltd (3-174 Atlantic Drive, Keysborough, VIC, 3173)

Sample Description: Densi Proof Plus X300 Surface Repeller

Date Tested: December 2015 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

Specification	Densi Proof Plus X300 Surface Repeller
<b>Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11</b>  Internal Sealer  65 grams per Litre as VOC content per mate	<b>Densi Proof Plus X300 Surface Repeller</b>  <1 grams per Litre as VOC content per material
<b>Green Building Council of Australia Green Star Office Design V3 IEQ-13</b>  Internal Sealer  65 grams per Litre as VOC content per material	<b>Densi Proof Plus X300 Surface Repeller</b>  <1 grams per Litre as VOC content per material

Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

Tuan Duong  
BE (Chem. Eng.)  
Consultant

Nick Joy  
BSc (Hons)  
Consultant

CV151201