



VOC Content Test Certificate

Thursday, 3rd December 2015

Manufacturer: Oxtek Australia Pty Ltd (3-174 Atlantic Drive, Keysborough, VIC, 3173)

Sample Description: X550 Carpark

Date Tested: December 2015 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in

Various Materials as referenced by South Coast Air Quality Management District
(SCAQMD) Rule 1168

Test Data:

<p>Specification</p> <p>Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11</p> <p>Internal Sealer</p> <p>65 grams per Litre as VOC content per mate</p>	<p>X550 Carpark</p> <p><1 grams per Litre as VOC content per material</p>
<p>Specification</p> <p>Green Building Council of Australia Green Green Star Office Design V3 IEQ-13</p> <p>Internal Sealer</p> <p>65 grams per Litre as VOC content per material</p>	<p>X550 Carpark</p> <p><1 grams per Litre as VOC content per material</p>

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Tuan Duong
BE (Chem. Eng.)
Consultant

Nick Joy
BSc (Hons)
Consultant

CV151201